



Date of Park and Recreation Advisory Board Meeting: July 19, 2018

To: Park and Recreation Advisory Board

From: Allison Watkins

Subject: Ice Arena and Pool

Action Requested: PRAB Discussion

Summary Report:

Arena:

- Late in June the compressors were not keeping temperature. We had 150 pounds of R-22 added to the system on Sunday June 24. Monday June 25 the temp climbed back up so we had Harris Mechanical come out and test for a leak. We did find a major leak in one of the fittings and a smaller leak in another fitting. We had another 150 pounds added and we fixed the major leak on the fitting. The smaller leak will be repaired after we shut down in August before we re-open in September. The sniffer alarm did not pick up either leak and be scheduled for an inspection.

Pool:

- Staff is looking at pool attendance numbers during the 11:30am time to potentially open in future seasons at 12:30pm instead. I would like to open up the idea of extending lap swim times and work with Community Services to extend the swim lesson times. The attendance from 11:30am (when the facility opens for public swim) to 12:30pm is very low. At this time I have 4 to 5 guards on and usually one stand or two stands up. The majority of patrons that use the pool are coming in around 12:30 and 1pm.
- Staff met with Brett from Flagship Recreation about adding a splash pad in the future to OMP. We are still waiting on Brett's report from that meeting.

Alternative Options:

N/A

Financial Information: